

CERTIFICATE OF COMPLIANCE

Certificate Number 20191115-EX26699
Report Reference EX26699-20150729
Issue Date 2019-NOVEMBER-15

Issued to: LINK YAPI SANAYI VE TICARET A S
Gebze Organize Sanayi Bolgesi
1000 Sokak No 1016
Cayirova / KOCAELI TURKEY

This certificate confirms that representative samples of HANGERS, PIPE
See Addendum Page

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 203, Pipe Hanger Equipment for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE


Certificate Number 20191115-EX26699
Report Reference EX26699-20150729
Issue Date 2019-NOVEMBER-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Pipe hangers

Model	Hanger Type	Rod Size, in. (mm)	NPS*	Comments
SP	Band	3/8 (M10)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	-
SP	Band	1/2 (M12)	5, 6, 8	-
SP	Band	5/8 (M16)	10, 12	-
DB	Clevis	3/8 (M10)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	-
DB	Clevis	1/2 (M12)	5, 6, 8	-
HDG	Clevis	3/8 (M10)	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4	-
HDG	Clevis	1/2 (M12)	5, 6, 8	-
LBC	Universal Beam Clamp	M10	Up to 4	-
LBC	Universal Beam Clamp	M12	Up to 8	-
SBH	Pipe Clamp	M10	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4	-
SBH	Pipe Clamp	M12	5, 6, 8	-
SBH	Pipe Clamp	M16	10, 12	-

NPS – Nominal Pipe Size



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

