



Certificate of Compliance

This certificate is issued for the following:

Seismic Sway Brace Components

(see listing attached)

Prepared for:

Link Yapi Sanayi Ve Ticaret AS
Gebze Organize Sanayi Bolgesi 1000 Sokak No 1016
Cayirova, Kocaeli 41400
Turkey

Manufactured at:

Link Yapi Sanayi Ve Ticaret AS
Gebze Organize Sanayi Bolgesi 1000 Sokak No 1016
Cayirova, Kocaeli 41400
Turkey

FM Approvals Class: 1950

Approval Identification: 3063173

Approval Granted: July 13, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Model/Code	Part Description	Orientation	Allowable Horizontal Capacity (F) per Installation Angle, lb (N)				Remarks
			30°-44°	45°-59°	60°-74°	75°-90°	
RSBE	Building Attachment	N/A	1890 (8400)	2670 (11870)	3460 (15390)	3490 (15520)	a, b, c
RSBA	Building Attachment	N/A	1780 (7910)	2520 (11200)	3120 (13870)	2530 (11250)	a, c

Model/Code	Part Description	Orientation	Run Pipe Nominal Size (in)	Run Pipe Reference	Allowable Horizontal Capacity (F) per Installation Angle, lb (N)				Remarks
					30°-44°	45°-59°	60°-74°	75°-90°	
RSBC	Pipe Attachment	Longitudinal	1, 1 1/2, 2, 2 1/2, 3	Sch 10 and 40	270 (1200)	430 (1910)	750 (3330)	920 (4090)	a, b, c, d
RSBC	Pipe Attachment	Longitudinal	4	Sch 10 and 40	860 (3820)	870 (3860)	1040 (4620)	1320 (5870)	a, b, c, d
RSBC	Pipe Attachment	Longitudinal	5, 6	Sch 10 and 40	680 (3020)	930 (4130)	810 (3600)	900 (4000)	a, b, c, d
RSBC	Pipe Attachment	Longitudinal	8	Sch 10 and 40	930 (4130)	1280 (5690)	870 (3860)	960 (4270)	a, b, c, d
RSBC	Pipe Attachment	Lateral	1, 1 1/4, 1 1/2, 2, 2 1/2, 3, 4, 5, 6	Sch 10 and 40	1770 (7870)	2510 (11160)	3080 (13700)	3430 (15250)	a, b, c, d
RSBC	Pipe Attachment	Lateral	8	Sch 10 and 40	1160 (5150)	1640 (7290)	2000 (8890)	2240 (9960)	a, b, c, d

Remarks

- a. FM Approved when used with 1 or 1 1/4 inch Sch. 40, GB/T3091, EN10255H or JISG3454 brace pipe.
- b. FM Approved with brace element of structural steel 1/4 to 3/8 inch thick.
- c. FM Approved when used with 1 1/4 inch Sch. 40, GB/T3091, EN10255H or JISG3454 brace pipe.
- d. Package is marked with code in the following format 0334.1.RSBC.x(size) where x=0 to attach to structural steel brace, x=1 to attach to 1 inch brace pipe and x=2 to attach to 1 1/4 inch brace pipe.



CERTIFICATE OF COMPLIANCE

Certificate Number 20180326-EX27136
Report Reference EX27136-20170620
Issue Date 2018-March-26

Issued to: LINK YAPI SANAYI VE TICARET A S
Gebze Organize Sanayi Bolgesi
1000 Sokak No 1016
Cayirova / KOCAELI TURKEY

**This is to certify that
representative samples of**

SWAY-BRACE DEVICES, RIGID TYPE FOR SPRINKLER
SYSTEMS

Structure Attachment Fitting, Models: RSBA, RSBE, RSBI
NPS = Nominal Pipe Size

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL Subject 203A, Outline of Investigation for Sway Brace
Devices for Sprinkler System Piping

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

