



# CERTIFICATE OF CONFORMITY

<b>Certificate - No.</b>	20-IS-1284-TAT-20-TPI-1249
<b>Applicant</b>	LİNK YAPI SANAYİ VE TİCARET A.Ş. Gebze Organize Sanayi Bölgesi 1000. Sokak No:1016 Çayırova / Kocaeli - TURKEY
<b>Manufacturer</b>	LİNK YAPI SANAYİ VE TİCARET A.Ş. Gebze Organize Sanayi Bölgesi 1000. Sokak No:1016 Çayırova / Kocaeli - TURKEY
<b>Product</b>	KNUK Beam Clamps
<b>Type/Model(s)</b>	KNUK.4060, KNUK.4060.01, KNUK.6080, KNUK.6080.01, KNUK.1000
<b>Test Standard(s)</b>	EAD 330155-00-0602

The tests of KNUK.4060, KNUK.4060.01, KNUK.6080, KNUK.6080.01, KNUK.1000 products produced by LİNK YAPI SANAYİ VE TİCARET A.Ş. were conducted under the witnessing of TUV AUSTRIA TURK auditors.

## The test results

### TEST DATA

Product Name	Max. Flange Thickness	Bolt			Test Type	Test No / Fail Load (kN)					Safety Factor	Recommended Safe Load (kN)
		Class	Size	Torque		1	2	3	4	Min.		
KNUK.4060	60 mm	8.8	M.10		Tensile (2 Bolt)	9,95	9,35	10,00	8,00	8,00	5,0	1,60
KNUK.4060.01	60 mm	8.8	M.12		Tensile (2 Bolt)	7,70	7,40	6,20	7,35	6,20	5,0	1,24
KNUK.6080	80 mm	8.8	M.10		Tensile (2 Bolt)	7,60	8,65	7,25	7,55	7,25	5,0	1,45
KNUK.6080.01	80 mm	8.8	M.12		Tensile (2 Bolt)	7,50	10,15	9,20	9,60	7,50	5,0	1,50
KNUK.1000	100 mm	8.8	M.12		Tensile (2 Bolt)	5,45	5,40	5,15	5,60	5,15	5,0	1,03

Final Report No : 20-IS-1284-TAT-20-0451

Issue Date : 11.08.2020

Expiry Date : 11.08.2021



This Certificate of Conformity has been granted to the applicant based on the results of testing performed by the applicant/manufacturer or an accepted laboratory and the consequent review of the test report by TÜV Austria Turk. Revisions to the referenced certification basis or any change of the design, materials, components or processing may require the repetition of all or some of the qualification tests in order for the test report and therefore this associated certificate to remain valid.